

July 20, 2011 – Hearing.

NOI from Doug Smith of SoilSmith for the Lightfoot property on Turnpike Road.

Opened the hearing at 8:00pm

Submitted copy of the newspaper notice. But didn't mail out the notice to the abutters.

Will have to continue the meeting until abutters are notified.

System and reserve system are outside the 100 ft buffer, but fill comes within 75 ft of the wetlands bound. Culvert was put into the driveway to cross the stream under a determination.

Only conditions will be around the protection of the slope of the septic system from siltation into the wetland. Use siltation fencing.

Marking of the wetland bounds will be part of the conditions.

Need a plan for the water from the driveway so that it is not dropped into the wetland.

Continue the hearing at 8:23 pm to August 3<sup>rd</sup>, 2011 @ 8:00pm