

October 4, 2017 9:00 - NOI for septic system replacement for Rodney and Donna Fors, 113 County Rd DEP # 93-368

Hearing opened

Donna and Rodney Fors, owners

Represented by Chris MacKenzie, Whitman and Bingham

Notice from paper was finally found online. Advertised on September 22, 2017.

Handed in Certified cards from the mailing. Town of Winchendon was referenced on much of the application.

Wetland runs the length of the property. Existing septic system has to be replaced. Variance – 3 ft ground water separation to drop the height of the system.

Existing gravel driveway to be used for access to the area. Ask to ensure that they don't use the trail out to the back of the property.

Condition:

Block cart path with a barrier.

Put poly barrier into the system – 2/1 slope – now 30 ft to toe of slope from the wetlands. Originally this was 20 ft. This is an improvement.

Jute matting and creeping juniper as a solution to stabilizing the slope.

Motion to close hearing and issue OOC. 2nd by Cathy. Unanimous in favor of the motion

Closed at 9:19pm Bob will write the OOC.